

## Fuel Oil Containment

### Links to applicable regulations

[33 CFR 155.320](#)

### Checklist for this item

	Containment capable of retaining spilled oil around fuel or bulk lubricating oil:
	<ul style="list-style-type: none"><li>• Tanks vents</li></ul>
	<ul style="list-style-type: none"><li>• Overflow piping</li></ul>
	<ul style="list-style-type: none"><li>• Fill piping</li></ul>
	Using one of the following containment methods:
	<ul style="list-style-type: none"><li>• Fixed <b>container</b> of ½ barrel (21 gal) capacity.</li></ul>
	<ul style="list-style-type: none"><li>• <b>or enclosed deck area</b> of ½ barrel (21 gal) capacity.</li></ul>
	<ul style="list-style-type: none"><li>• <b>or portable container</b> (5 gal) capacity.</li></ul>

**Note:** If the vessel has a fill fitting for which containment is impractical, an automatic back pressure shut-off nozzle must be used.