

Fuel Oil Containment

Links to applicable regulations

[33 CFR 155.320](#)

Checklist for this item

	Containment capable of retaining spilled oil around fuel or bulk lubricating oil:
	<ul style="list-style-type: none">• Tanks vents
	<ul style="list-style-type: none">• Overflow piping
	<ul style="list-style-type: none">• Fill piping
	Vessels constructed before July 1, 1974.
	<ul style="list-style-type: none">• Fixed container of ½ barrel (21 gal) capacity.
	<ul style="list-style-type: none">• or enclosed deck area of ½ barrel (21 gal) capacity
	<ul style="list-style-type: none">• or portable container (5 gal) capacity.
	Vessels constructed after June 30, 1974
	<ul style="list-style-type: none">○ Fixed container of one barrel (42 gal) capacity..
	<ul style="list-style-type: none">○ or enclosed deck area of one barrel (42 gal) capacity..

Note: If the vessel has a fill fitting for which containment is impractical, an automatic back pressure shut-off nozzle must be used.