

General Alarm Flashing Light

Links to applicable regulations

[46 CFR 28.240\(c\) - Requirement](#)

Checklist for this item

	A general alarm system installed on a vessel with work spaces that are so loud that the general alarm signal might not be heard must have a flashing red light installed in those spaces.
	<ul style="list-style-type: none">• The lights location must be so that it can be seen from any area in the space.
	<ul style="list-style-type: none">• Each flashing red light must be identified with ½ inch red letters:
	<div style="border: 1px solid black; padding: 10px; text-align: center;"><p>ATTENTION</p><p>GENERAL ALARM</p><p>When Alarm Sounds</p><p>Go To Your Station</p></div>
	Visually check to ensure that the light(s) are working during testing of the general alarm system;