

of the largest compartment to be protected.

(3) Although separate piping shall be led to each cargo hold and 'tween deck, for the purpose of determining the amount of steam required, a cargo compartment will be considered as the space between adjacent watertight or firescreen bulkheads and from tank top or lowest deck to the deck head of the uppermost deck on which cargo may be carried. If a trunk extends beyond such deck, the trunk space shall be included. Tonnage openings shall be considered as sealed for this purpose.

(4) A steam pressure of at least 100 p.s.i. shall be available unless specifically approved otherwise.

(5) All piping, valves, and fittings shall meet the applicable requirements of subchapter F (Marine Engineering) of this chapter.

(6) The distribution piping shall emanate from not more than three stations in easily accessible locations on the weather deck, and shall lead to the lower portion of each cargo hold, cargo 'tween deck, and other compartments protected. However, lines to paint lockers and similar small spaces may be taken from the nearest steam supply line.

(7) The distribution line to each compartment shall be fitted with a shutoff valve. The valve shall be marked as required by § 78.47-15 of this subchapter.

(8) The manifold steam supply line shall be fitted with a master valve at the manifold.

(9) Provisions shall be made for draining the manifold and distribution lines to prevent them from freezing.

(10) If located on the open deck, the distribution manifolds shall be suitably protected by an enclosing cabinet or casing. In any case, it shall be marked as required by § 78.47-17 of this subchapter.

(11) Piping shall not be led into or through spaces accessible to the passengers or crew while the vessel is being navigated, with the exception of machinery spaces and corridors. However, in special cases, arrangements to run piping through such spaces may be specifically approved by the Commandant, provided all joints are welded, suitable expansion bends are provided, and all piping is extra heavy.

(12) Piping shall be used for no other purpose except that it may be incorporated with the fire detecting system, and where suitable provisions are made, it may be used for steaming out tanks.

(13) The minimum size and number of branches to the various spaces shall be as given in table 76.13-90(c)(13). The distribution piping from the manifold to the branch lines shall have an area approximately equal to the combined areas of the branch lines served.

TABLE 76.13-90(c)(13)

Volume of spaces in cubic feet		Number of branches to spaces	Pipe size of each branch, inches
Over	Not over		
.....	500	1	¾
500	5,000	1	1
5,000	15,000	1	1¼
15,000	30,000	1	1½
30,000	60,000	2	1½
60,000	100,000	3	1½
100,000	190,000	4	1½

(14) The steam supply line from the boiler to any distribution manifold shall be of sufficient size to supply all the branch lines to the largest compartment and to all adjacent compartments.

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965, as amended by CGFR 66-33, 31 FR 15283, Dec. 6, 1966]

Subpart 76.15—Carbon Dioxide Extinguishing Systems, Details

§ 76.15-1 Application.

(a) Where a carbon dioxide extinguishing system is installed, the provisions of this subpart, with the exception of § 76.15-90, shall apply to all installations contracted for on or after November 19, 1952. Installations contracted for prior to November 19, 1952, shall meet the requirements of § 76.15-90.

(b) The requirements of this subpart are based on a "high pressure system", i.e., one in which the carbon dioxide is stored in liquid form at atmospheric temperature. Details for "low pressure systems", i.e., those in which the carbon dioxide is stored in liquid form at a continuously controlled low temperature, may be specifically approved by

§ 76.15-5

the Commandant where it is demonstrated that a comparable degree of safety and fire extinguishing ability is achieved.

§ 76.15-5 Quantity, pipe sizes, and discharge rate.

(a) *General.* The amount of carbon dioxide required for each space shall be as determined by the following paragraphs in this section.

(b) *Total available supply.* A separate supply of carbon dioxide need not be provided for each space protected. The total available supply shall be at least sufficient for the space requiring the greatest amount.

(c) *Cargo spaces.* (1) The number of pounds of carbon dioxide required for each space in cubic feet shall be equal to the gross volume of the space in cubic feet divided by 30.

(2) Although separate piping shall be led to each cargo hold and 'tween deck, for the purpose of determining the amount of carbon dioxide required, a cargo compartment will be considered as the space between adjacent watertight or firescreen bulkheads and from the tank top or lowest deck to the deck head of the uppermost space on which cargo may be carried. If a trunk extends beyond such deck, the trunk volume shall be included. Tonnage openings shall be considered as sealed for this purpose.

(3) Branch lines to the various cargo holds and 'tween decks shall not be less than 3/4 inch standard pipe size.

(4) No specific discharge rate need be applied to such systems.

(d) *Machinery spaces, paint lockers, tanks, and similar spaces.* (1) Except as provided in paragraph (d)(3) of this section, the number of pounds of carbon dioxide required for each space shall be equal to the gross volume of the space divided by the appropriate factor noted in table 76.15-5(d)(1). If fuel can drain from the compartment being protected to an adjacent compartment, or if the compartments are not entirely separate, the requirements for both compartments shall be used to determine the amount of carbon dioxide to be provided. The carbon dioxide shall be arranged to discharge into both such compartments simultaneously.

46 CFR Ch. I (10-1-08 Edition)

TABLE 76.15-5(d)(1)

Gross volume of compartment, cubic feet		Factor
Over	Not over	
	500	15
500	1,600	16
1,600	4,500	18
4,500	50,000	20
50,000		22

(2) For the purpose of the above requirement of this paragraph, the volume of a machinery space shall be taken as exclusive of the normal machinery casing unless the boiler, internal combustion machinery, or fuel oil installations extend into such space in which case the volume shall be taken to the top of the casing or the next material reduction in casing area, whichever is lower. For installations contracted for on or after October 1, 1959, "normal machinery casing" and "material reduction in casing area" shall be defined as follows:

(i) By "normal machinery casing" shall be meant a casing the area of which is not more than 40 percent of the maximum area of the machinery space.

(ii) By "material reduction in casing area" shall be meant a reduction to at least 40 percent of the casing area.

(3) For vessels on an international voyage contracted for on or after May 26, 1965, the amount of carbon dioxide required for a space containing propulsion boilers or internal combustion propulsion machinery shall be as given by paragraphs (d) (1) and (2) of this section or by dividing the entire volume, including the casing, by a factor of 25, whichever is the larger.

(4) Branch lines to the various spaces shall be as noted in table 76.15-5(d)(4).

TABLE 76.15-5(d)(4)

Maximum quantity of carbon dioxide required, pounds	Minimum nominal pipe size, inches	Maximum quantity of carbon dioxide required, pounds	Minimum nominal pipe size, inches
100	1/2	2,500	2 1/2
225	3/4	4,450	3
300	1	7,100	3 1/2
600	1 1/4	10,450	4
1,000	1 1/2	15,000	4 1/2
2,450	2		

(5) Distribution piping within the space shall be proportioned from the supply line to give proper distribution to the outlets without throttling.

(6) The number, type, and location of discharge outlets shall be such as to give a uniform distribution throughout the space.

(7) The total area of all discharge outlets shall not exceed 85 percent nor be less than 35 percent of the nominal cylinder outlet area or the area of the supply pipe, whichever is smaller. The nominal cylinder outlet area in square inches shall be determined by multiplying the factor 0.0022 by the number of pounds of carbon dioxide required, except that in no case shall this outlet area be less than 0.110 square inch.

(8) The discharge of at least 85 percent of the required amount of carbon dioxide shall be complete within 2 minutes.

(e) *Spaces specially suitable for vehicles.* (1) The number of pounds of carbon dioxide required shall be equal to the gross volume of the largest "tight" space divided by 22. In no case, however, shall it be less than that required by paragraph (c) of this section.

(2) The arrangement of valves and piping shall be such that the required quantity of carbon dioxide may be discharged into any "tight" space. The discharge of the required quantity of carbon dioxide shall be completed within 2 minutes.

(3) Except as noted in paragraphs (e) (1) and (2) of this section, the requirements of paragraph (e) of this section shall apply.

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965, as amended by CGFR, 66-33, 31 FR 15283, Dec. 6, 1966; CGD 95-028, 62 FR 51204, Sept. 30, 1997; USCG-1999-6216, 64 FR 53225, 53226, Oct. 1, 1999]

§ 76.15-10 Controls.

(a) Except as noted in § 76.15-20(b), all controls and valves for the operation of the system shall be outside the space protected, and shall not be located in any space that might be cut off or made inaccessible in the event of fire in any of the spaces protected.

(b) If the same cylinders are used to protect more than one hazard, a manifold with normally closed stop valves shall be used to direct the carbon dioxide

into the proper space. If cylinders are used to protect only one hazard, a normally closed stop valve shall be installed between the cylinders and the hazard except for systems of the type indicated in § 76.15-5(d) which contain not more than 300 pounds of carbon dioxide.

(c) Distribution piping to the various cargo spaces shall be controlled from not more than two stations. One of the stations controlling the system for the main machinery space shall be located as convenient as practicable to one of the main escapes from the space. All control stations and the individual valves and controls shall be marked as required by §§ 78.47-15 and 78.47-17 of this subchapter.

(d) Systems of the type indicated in § 76.15-5(d) shall be actuated by one control operating the valve to the space and a separate control releasing at least the required amount of carbon dioxide. These two controls shall be located in a box or other enclosure clearly identified for the particular space. Those systems installed without a stop valve shall be operated by one control releasing at least the required amount of carbon dioxide.

(e) Where provisions are made for the simultaneous release of a given amount of carbon dioxide by operation of a remote control, provisions shall also be made for manual control at the cylinders. Where gas pressure from pilot cylinders is used as a means for releasing the remaining cylinders, not less than two pilot cylinders shall be used for systems consisting of more than two cylinders. Each of the pilot cylinders shall be capable of manual control at the cylinder, but the remaining cylinders need not be capable of individual manual control.

(f) Systems of the type indicated in § 76.15-5(d), other than systems for tanks, which are of more than 300 pounds of carbon dioxide, shall be fitted with an approved delayed discharge so arranged that the alarm will be sounded for at least 20 seconds before the carbon dioxide is released into the space. Such systems of not more than 300 pounds of carbon dioxide shall also have a similar delayed discharge, except for those systems for tanks and

for spaces which have a suitable horizontal escape. This paragraph shall be applicable only to systems installed on or after July 1, 1957.

(g) All distribution valves and controls shall be of an approved type. All controls shall be suitably protected.

(h) Complete but simple instructions for the operation of the systems must be located in a conspicuous place at or near all pull boxes, stop valve controls and in the CO₂ cylinder storage room. On systems in which the CO₂ cylinders are not within the protected space, these instructions must also include a schematic diagram of the system and instructions detailing alternate methods of discharging the system should the manual release or stop valve controls fail to operate. Each control valve to branch lines must be marked to indicate the related space served.

(i) If the space or enclosure containing the carbon dioxide supply or controls is to be locked, a key to the space or enclosure shall be in a break-glass-type box conspicuously located adjacent to the opening.

[CGFR 65-60, 30 FR 16940, Dec. 30, 1965, as amended by CGD 74-100R, 40 FR 6209, Feb. 10, 1975; USCG-1999-6216, 64 FR 53226, Oct. 1, 1999]

§76.15-15 Piping.

(a) The piping, valves, and fittings shall have a bursting pressure of not less than 6,000 p.s.i.

(b) All piping, in nominal sizes not over ¾ inch, shall be at least Schedule 40 (standard weight), and in nominal sizes over ¾ inch, shall be at least Schedule 80 (extra heavy).

(c) All piping, valves, and fittings of ferrous materials shall be protected inside and outside against corrosion unless specifically approved otherwise by the Commandant.

(d) A pressure relief valve or equivalent set to relieve between 2,400 and 2,800 p.s.i. shall be installed in the distributing manifold or such other location as to protect the piping in the event that all branch line shut-off valves are closed.

(e) All dead end lines shall extend at least 2 inches beyond the last orifice and shall be closed with cap or plug.

(f) All piping, valves, and fittings shall be securely supported, and where necessary, protected against injury.

(g) Drains and dirt traps shall be fitted where necessary to prevent the accumulation of dirt or moisture. Drains and dirt traps shall be located in accessible locations where possible.

(h) Piping shall be used for no other purpose except that it may be incorporated with the fire detecting system.

(i) Piping passing through living quarters shall not be fitted with drains or other openings within such spaces.

(j) Installation test requirements:

(1) Upon completion of the piping installation, and before the cylinders are connected, a pressure test shall be applied as set forth in this paragraph. Only carbon dioxide or other inert gas shall be used for this test.

(2) The piping from the cylinders to the stop valves in the manifold shall be subjected to a pressure of 1,000 p.s.i. With no additional gas being introduced to the system, it shall be demonstrated that the leakage of the system is such as not to permit a pressure drop of more than 150 p.s.i. per minute for a 2-minute period.

(3) The individual branch lines to the various spaces protected shall be subjected to a test similar to that described in the preceding paragraph with the exception that the pressure used shall be 600 p.s.i. in lieu of 1,000 p.s.i. For the purpose of this test, the distribution piping shall be capped within the space protected at the first joint ahead of the nozzles.

(4) In lieu of the tests prescribed in the preceding paragraphs in this section, small independent systems protecting spaces such as emergency generator rooms, lamp lockers, etc., may be tested by blowing out the piping with air at a pressure of at least 100 p.s.i.

§76.15-20 Carbon dioxide storage.

(a) Except as provided in paragraph (b) of this section, the cylinders shall be located outside the spaces protected, and shall not be located in any space that might be cut off or made inaccessible in the event of a fire in any of the spaces protected.

(b) Systems of the type indicated in §76.15-5(d), consisting of not more than 300 pounds of carbon dioxide, may have the cylinders located within the space protected. If the cylinder stowage is

within the space protected, the system shall be arranged in an approved manner to be automatically operated by a heat actuator within the space in addition to the regular remote and local controls.

(c) The space containing the cylinders shall be properly ventilated and designed to preclude an anticipated ambient temperature in excess of 130 degrees F.

(d) Cylinders shall be securely fastened and supported, and, where necessary, protected against injury.

(e) Cylinders shall be so mounted as to be readily accessible and capable of easy removal for recharging and inspection. Provisions shall be available for weighing the cylinders.

(f) Where subject to moisture, cylinders shall be so installed as to provide a space of at least 2 inches between the flooring and the bottom of the cylinders.

(g) Cylinders shall be mounted in an upright position or inclined not more than 30 degrees from the vertical. However, cylinders which are fitted with flexible or bent syphon tubes may be inclined not more than 80 degrees from the vertical.

(h) Where check valves are not fitted on each independent cylinder discharge, plugs or caps shall be provided for closing outlets when cylinders are removed for inspection or refilling.

(i) All cylinders used for storing carbon dioxide must be fabricated, tested, and marked in accordance with §§ 147.60 and 147.65 of this chapter.

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965, as amended by CGD 84-044, 53 FR 7748, Mar. 10, 1988; USCG-1999-6216, 64 FR 53226, Oct. 1, 1999]

§ 76.15-25 Discharge outlets.

(a) Discharge outlets shall be of an approved type.

(b) [Reserved]

§ 76.15-30 Alarms.

(a) Spaces which are protected by a carbon dioxide extinguishing system and are normally accessible to persons on board while the vessel is being navigated, other than paint and lamp lockers and similar small spaces, shall be fitted with an approved audible alarm in such spaces which will be automatically sounded when the carbon dioxide

is admitted to the space. The alarm shall be conspicuously and centrally located and shall be marked as required by § 78.47-9 of this subchapter. For systems installed on or after July 1, 1957, alarms will be mandatory only for systems required to be fitted with a delayed discharge. Such alarms shall be so arranged as to sound during the 20 second delay period prior to the discharge of carbon dioxide into the space, and the alarm shall depend on no source of power other than the carbon dioxide.

(b) [Reserved]

§ 76.15-35 Enclosure openings.

(a) Where mechanical ventilation is provided for spaces other than cargo and similar spaces which are protected by a carbon dioxide extinguishing system, provisions shall be made so that the ventilation system is automatically shut down with the operation of the system to that space.

(b) Where natural ventilation is provided for spaces protected by a carbon dioxide extinguishing system, provisions shall be made for easily and effectively closing off the ventilation.

(c) Means shall be provided for closing all openings to the space protected from outside such space. In this respect, relatively tight doors, shutters, or dampers shall be provided for openings in the lower portion of the space. The construction shall be such that openings in the upper portion of the space can be closed off either by permanently installed means or by the use of canvas or other material which is normally carried by the vessel.

§ 76.15-40 Pressure relief.

(a) Where necessary, relatively tight compartments such as refrigeration spaces, paint lockers, etc., shall be provided with suitable means for relieving excessive pressure accumulating within the compartment when the carbon dioxide is injected.

(b) [Reserved]

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965, as amended by CGFR 66-33, 31 FR 15283, Dec. 6, 1966]

§ 76.15-90

46 CFR Ch. I (10-1-08 Edition)

§ 76.15-90 Installations contracted for prior to November 19, 1952.

discharge outlets and siphon tubes of 3/8-inch diameter.

(a) Installations contracted for prior to November 19, 1952, shall meet the following requirements:

(1) Existing arrangements, materials, and facilities previously approved shall be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original installation.

(2) The details of the systems shall be in general agreement with §§ 76.15-5 through 76.15-40 insofar as is reasonable and practicable, with the exception of § 76.15-5(d) (1) through (3) covering spaces other than cargo spaces, which systems may be installed in accordance with paragraphs (a) (3) through (6) of this section. However, the foregoing exception shall not be permitted for vessels on an international voyage.

(3) In boilerrooms, the bilges shall be protected by a system discharging principally below the floor plates. Perforated pipe may be used in lieu of discharge nozzles for such systems. The number of pounds of carbon dioxide shall be equal to the gross volume of the boiler room taken to the top of the boilers divided by 36. In the event of an elevated boilerroom which drains to the machinery space, the system shall be installed in the engine room bilge and the gross volume shall be taken to the flat on which the boilers are installed.

(4) In machinery spaces where main propulsion internal combustion machinery is installed, the number of pounds of carbon dioxide required shall be equal to the gross volume of the space taken to the underside of the deck forming the hatch opening divided by 22.

(5) In miscellaneous spaces other than cargo or main machinery spaces, the number of pounds of carbon dioxide required shall be equal to the gross volume of the space divided by 22.

(6) Branch lines to the various spaces other than cargo and similar spaces, shall be as noted in table 76.15-90(a)(6). This table is based on cylinders having

TABLE 76.15-90(a)(6)

Number of cylinders		Nominal pipe size	
Over	Not over	Inches	Type
.....	2	1/2	Standard.
2	4	3/4	Do.
4	6	1	Extra heavy.
6	12	1 1/4	Do.
12	16	1 1/2	Do.
16	27	2	Do.
27	39	2 1/2	Do.
39	60	3	Do.
60	80	3 1/2	Do.
80	104	4	Do.
104	165	5	Do.

(b) [Reserved]

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965, as amended by CGFR 67-87, 32 FR 19181, Dec. 20, 1967; USCG-1999-6216, 64 FR 53226, Oct. 1, 1999]

Subpart 76.17—Foam Extinguishing Systems, Details

§ 76.17-1 Application.

(a) Where a foam extinguishing system is installed, the provisions of this subpart, with the exception of § 76.17-90, shall apply to all installations contracted for on or after November 19, 1952. Installations contracted for prior to November 19, 1952, shall meet the requirements of § 76.17-90.

(b) [Reserved]

§ 76.17-5 Quantity of foam required.

(a) *Area protected.* (1) For machinery and similar spaces, the system shall be so designed and arranged as to spread a blanket of foam over the entire tank top or bilge of the space protected. The arrangement of piping shall be such as to give a uniform distribution over the entire area protected.

(2) Where an installation is made to protect an oil fired boiler installation on a flat which is open to or can drain to the lower engine room or other space, both the flat and the lower space shall be protected simultaneously. The flat shall be fitted with suitable coamings on all openings other than deck drains to properly restrain the oil and foam at that level. Other installations of a similar nature will be considered in a like manner.

(3) Where a system is installed to protect a tank, it shall be so designed