

MSC Guidelines for Review of Suppression in Galley Ducts

Procedure Number: SOLAS-11

Revision Date: 06/16/2010

Randy J. Jenkins

R. J. JENKINS, LCDR, Chief, Major Vessel Branch

References	<ul style="list-style-type: none">❑ SOLAS 2004 Cite: II-2/9.7.5.1.3❑ SOLAS 2001 Cite: II-2/32.1.9.3
Contact Information	<p>If you have any questions or comments concerning this document, please contact the Marine Safety Center by e-mail or phone. Please refer to Procedure Number: SOLAS-11.</p> <p>E-Mail: msc@uscg.mil Phone: (202) 475-3401</p>
Reference Text	<p>“...a fixed means for extinguishing a fire within the duct.”</p>
Guidance	<p>Fixed extinguishing systems should be sized to provide protection for the entire volume of ducting between the dampers required by 9.7.5.1.2.</p>
Background	<p>Given the large length of typical main galley ventilation ducts, it is necessary to clarify the extent of fixed extinguishing protection within the duct.</p>
Disclaimer	<p>This guidance is not a substitute for applicable legal requirements, nor is it itself a rule. It is not intended to nor does it impose legally-binding requirements on any party. It represents the Coast Guard’s current thinking on this topic and may assist industry, mariners, the general public, and the Coast Guard, as well as other federal and state regulators, in applying statutory and regulatory requirements. You can use an alternative approach for complying with these requirements if the approach satisfies the requirements of the applicable statutes and regulations. If you want to discuss an alternative, you may contact The Marine Safety Center, who is responsible for implementing this guidance.</p>
